

SSO Notification List

April 2013

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	4/1/2013	1601 N. Fulton Ave	21217	Rags & Grease	WWO	Jones Falls	1:00	1:32PM - 2:32PM	Heavy Gray Water	180	Pressure Jet relieved Mainline choke	Turn over to CCTV	156993
2	4/1/2013	1809 Bolton St	21217	Rags	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	156991
3	4/2/2013	3101 Pulaski Hwy	21224	Rags	DWO	Inner Harbor	20:20	4:02:13 5:15PM - 4:03:13 1:35PM	Sewer Water	2,440	Pressure Jet relieved Mainline choke	Turn over to CCTV	157091
4	4/3/2013	914 N. Monroe St	21217	Roots & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	157127
5	4/3/2013	5604 Purlington Way	21212	Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	157160
6	4/4/2013	805 W. Cross St	21230	Rags	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	157241
7	4/4/2013	2551 Marbourne Ave	21230	Roots & Debris	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	157179
8	4/4/2013	3703 Fallstaff Rd	21215	Rags & Roots	WWO	Gwynns Falls	3:20	10:15AM - 1:35PM	Sewer Water	1,000	Pressure Jet relieved Mainline choke	Turn over to CCTV	157197
9	4/4/2013	4440 Newport Ave	21211	Roots	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	157188
10	4/4/2013	Mondawmin Ave & Clifton Rd	21216	Roots	WWO	Gwynns Falls	0:25	9:35AM - 10:00AM	Heavy Gray Water	25	Pressure Jet relieved Mainline choke	Turn over to CCTV	157186
11	4/5/2013	2518 Talbot Rd	21216	Rags & Grease	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	N/A	157304
12	4/5/2013	3617 Hillisdale Rd	21207	N/A	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	157265
13	4/5/2013	4536 Schenley Rd	21210	Rags	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	157299
14	4/6/2013	6019 Loch Raven Rd	21239	Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	157364
15	4/7/2013	2337 Edmondson Ave	21223	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	157383
16	4/7/2013	3038 Dillon St	21224	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	N/A
17	4/7/2013	3626 Greenmount Ave	21218	Cable hung in connection	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Sewer Water & Debris	Evidence of Overflow	Turned over to construction	Removed cable from	150851
18	4/8/2013	6 Elmwood Rd	21210	Rags & Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	157447
19	4/8/2013	7003 Survey Dr	21215	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	157437
20	4/9/2013	604 Venable St	21218	Rags & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Wet around Cleanout	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	157471
21	4/9/2013	3834 Lewin Ave	21215	Rags & Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	157433
22	4/10/2013	8 Elmwood Rd	21210	Rags & Roots	DWO	Jones Falls	1:43	9:17AM - 11:00AM	Heavy Gray Water	309	Pressure Jet relieved Mainline choke	Turn over to CCTV	157531
23	4/10/2013	724 N. Fulton Ave	21217	Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	157532
24	4/10/2013	2337 Edmondson Ave	21223	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	157542
25	4/10/2013	5512 Boxhill Ln	21210	Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	157546
26	4/11/2013	301 Rossiter Ave	21212	Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	157680
27	4/11/2013	432 Ilchester Ave	21218	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	157687
28	4/11/2013	1134 N. Gilmor St	21217	Rags & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Wet around Cleanout	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	157549
29	4/11/2013	1809 Rayner Ave	21217	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	P/M to remove C/O cap	Call back when cap is removed	SR#108173
30	4/11/2013	2730 Wilmarco St	21223	Rags & Grease	DWO	Gwynns Falls	18:00	4:10:13 6:00PM - 4:11:13 12:00PM	Gray Colored Water	5,400	Pressure Jet relieved Mainline choke	Turn over to CCTV	157580
31	4/11/2013	3434 Park Heights Ave	21215	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Wet around Cleanout	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	157642
32	4/12/2013	503 Edgevale Rd	21210	Rags	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	157776
33	4/13/2013	320 Millington Ave	21223	Rags & Grease	DWO	None	0:30	5:30PM - 6:00PM	Gray Colored Water	15	Electric Machine relieved House Connection choke	Turn over to CCTV	157870
34	4/14/2013	6 Boulder Ln	21210	Roots	DWO	Jones Falls	0:08	10:50AM - 10:58AM	Gray Water	320	Pressure Jet relieved Mainline choke	Turn over to CCTV	157892
35	4/14/2013	1614 Braddish Ave	21216	Rags & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Gray Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	157896
36	4/14/2013	5906 Edna Ave	21214	Rags & Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	157905
37	4/15/2013	137 S. Loudon Ave	21229	Rags & Grease	WWO	Gwynns Falls	1:48	12:23PM - 2:11PM	Heavy Gray Water	216	Pressure Jet relieved Mainline choke	Turn over to CCTV	157989
38	4/15/2013	305 Somerset Rd	21210	Rags	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	158004
39	4/15/2013	4002 Kathland Ave	21207	Rags, Roots, Grease & Debris	WWO	Gwynns Falls	3:19	9:56AM - 1:23PM	Heavy Gray Water	995	Pressure Jet relieved Mainline choke	Turn over to CCTV	157968
40	4/15/2013	6701 Quad Ave	21205	N/A	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Wet Paper on the ground	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	157974
41	4/16/2013	432 Ilchester Ave	21218	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris & Feces	Evidence of Overflow	N/A	Turn over to CCTV	158096
42	4/16/2013	1029 Cooks Ln	21229	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	158083
43	4/16/2013	2119 Kentucky Ave	21218	Rags & Grease	DWO	None	0:30	10:00AM - 10:30AM	Gray Colored Water	15	Electric Machine relieved House Connection choke	Turn over to CCTV	157042
44	4/16/2013	4426 Forestview Ave	21206	Rags & Grease	DWO	None	1:00	2:30PM - 3:30PM	Gray Colored Water	30	Electric Machine relieved House Connection choke	Turn over to CCTV	158070
45	4/17/2013	500 Doswell Ave	21223	Rags & Grease	DWO	Gwynns Falls	1:10	8:50PM - 10:00PM	Sewer Water, Grease	350	Pressure Jet relieved Mainline choke	Turn over to CCTV	158180
46	4/17/2013	1117 Appleton St	21217	Rags & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Heavy Gray Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	158078
47	4/17/2013	2840 Greenmount Ave	21218	Rags & Grease	DWO	None	0:30	12:00PM - 12:30PM	Gray Colored Water	30	Electric Machine relieved House Connection choke	Turn over to CCTV	158129
48	4/17/2013	5816 Berkeley Ave	21215	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	158151

SSO Notification List

April 2013

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
49	4/19/2013	432 Ilchester Ave	21218	Rags	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris & Sewer Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	153235
50	4/19/2013	2324 W. Fayette St	21223	Unknown	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Left Notice can't get to C/O gate locked	N/A	158289
51	4/19/2013	3101 Pulaski Hwy	21224	Rags & Grease	WWO	Inner Harbor	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	158306
52	4/20/2013	1009 Appleton St	21217	N/A	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	158308
53	4/21/2013	914 N. Monroe St	21217	Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	158362
54	4/21/2013	4400 Wabash Ave	21215	Rags & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Heavy Gray Water	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	158348
55	4/22/2013	1307 W. Northern Pkwy	21209	Unknown	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Left Notice	N/A	158447
56	4/22/2013	3801 6th St	21225	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	153429
57	4/23/2013	3303 Elbert St	21229	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	158512
58	4/24/2013	1307 W. Northern Pkwy	21209	Rags & Roots	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	158541
59	4/24/2013	3208 Taney Rd	21215	Rags & Roots	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	158531
60	4/24/2013	3700 Reisterstown Rd	21215	Rags	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	158549
61	4/25/2013	1427 Homestead St	21218	Rags & Grease	DWO	Herring Run	0:37	10:00AM - 10:37AM	Clear Colored Water	37	Electric Machine relieved House Connection choke	Turn over to CCTV	158630
62	4/25/2013	1521 Park Ave	21217	Rags, Grease & Debris	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	158655
63	4/25/2013	4801 Lorrelly Ave	21206	Rags, Grease & Trash	DWO	Herring Run	3:20	9:00AM - 12:20PM	Clear Colored Water	1,000	Electric Machine relieved House Connection choke	Possibly Grease Control	158624
64	4/27/2013	508 S. Hanover St	21201	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	158776
65	4/27/2013	1828 Laurens St	21217	Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	158762
66	4/27/2013	6013 Park Heights Ave	21215	Pipe Break	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	158773
67	4/28/2013	3800 8th St	21225	Rags	WWO	Patapsco	5:50	12:50PM - 6:40PM	Heavy Gray Water	700	Pressure Jet relieved Mainline choke	Turn over to CCTV	158791
68	4/29/2013	6705 Western Run Dr	21215	Rags & Roots	WWO	Gwynns Falls	1:03	8:53AM - 9:56AM	Heavy Gray Water	63	Pressure Jet relieved Mainline choke	Turn over to CCTV	158805
69	4/30/2013	3703 Fallstaff Rd	21215	N/A	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	N/A	N/A	158880
				# WWO	25				TOTAL	13,095	EVIDENCE ONLY	51	