

SSO Notification List

March 2013

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	3/1/2013	2021 Madison Ave	21217	Rags & Roots	DWO	Jones Falls	3:08	12:07PM - 3:15PM	Gray Water	564	Electric Machine relieved House Connection choke	Turn over to CCTV	154665
2	3/1/2013	Beech Ave & W. 34th St	21211	Grease	DWO	Jones Falls	1:14	11:46AM - 1:00PM	Gray Water	296	Pressure Jet relieved Mainline choke	Flush Main	154663
3	3/2/2013	1000 Poplar Hill Rd	21210	Roots	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	154708
4	3/2/2013	2800 Rosalind Ave	21215	N/A	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Gray Water	Evidence of Overflow	N/A	N/A	154712
5	3/2/2013	4335 Eldone Rd	21229	Rags & Roots	WVO	Gwynns Falls	0:44	7:16PM - 8:00PM	Gray Water	176	Pressure Jet relieved Mainline choke	Turn over to CCTV	154722
6	3/2/2013	4501 Penhurst Ave	21215	N/A	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Gray Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	154697
7	3/3/2013	4812 Sipple Ave	21206	Roots	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	154735
8	3/3/2013	6415 Falkirk Rd	21239	Roots	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	154747
9	3/4/2013	1845 W. North Ave	21217	MVA	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	15789
10	3/4/2013	4909 Herring Run Dr	21214	Grease	DWO	Herring Run	2:15	1:45Pm - 4:00PM	Gray Water	675	Pressure Jet relieved Mainline choke	Turn over to CCTV	154996
11	3/4/2013	Ashburton St & Lanvale St	21216	Grease	DWO	Gwynns Falls	0:31	2:01PM - 2:32PM	Heavy Gray Water	93	Pressure Jet relieved Mainline choke	Turn over to CCTV	154781
12	3/5/2013	412 George St	21201	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	154829
13	3/5/2013	531 Random Rd	21229	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	154868
14	3/5/2013	2021 Madison Ave	21217	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	154828
15	3/5/2013	E. Northern Pkwy & Laurelton Ave	21239	Rags & Grease	DWO	Herring Run	1:13	10:10AM - 11:23AM	Gray Water	365	Pressure Jet relieved Mainline choke	Turn over to CCTV	154859
16	3/6/2013	4417 Kathland Ave	21207	Rags	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	155378
17	3/6/2013	4719 Shamrock Ave	21206	Rags & Grease	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	155469
18	3/7/2013	18 Gorman Ave	21223	Roots & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	155628
19	3/7/2013	320 Millington ave	21223	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	155605
20	3/7/2013	518 N. Rock Glen Rd	21229	Rags & Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	155595
21	3/7/2013	931 Montpelier St	21218	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	155835
22	3/7/2013	2700 Chelsea Ter	21216	Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	155819
23	3/7/2013	2801 Goodwood Rd	21214	N/A	DWO	Herring Run	18:30	3/07/13 7:15PM - 3/08/13 1:45PM	Gray Water	1,110	Electric Machine relieved House Connection choke	Turn over to CCTV	155642
24	3/7/2013	2920 Rockrose Ave	21215	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	155607
25	3/7/2013	4002 Kathland Ave	21207	Rags & Grease	DWO	Jones Falls	4:08	10:52AM - 3:00PM	Heavy Gray Water	744	Pressure Jet relieved Mainline choke	Turn over to CCTV	N/A
26	3/7/2013	4907 Frankford Ave	21206	Rags & Grease	DWO	Herring Run	15:40	3/07/13 6:20PM - 3/08/13 10:00AM	Gray Water, Grease & Debris	940	Electric Machine relieved House Connection choke	Turn over to CCTV	155638
27	3/8/2013	300 E. Madison St	21202	Rags, Grease & Trash	DWO	Jones Falls	3:00	2:30PM - 5:30PM	Plastic Bags, Toilet Paper & Orange Peelings	1,800	Pressure Jet relieved Mainline choke	Turn over to CCTV	155684
28	3/9/2013	708 Harvey St	21230	Grease	DWO	Inner Harbor	1:40	10:50AM - 12:30PM	Grease & Gray Water	200	Electric Machine relieved House Connection choke	Turn over to CCTV	155707
29	3/9/2013	3109 Granada Ave	21207	Grease	DWO	None	2:00	12:30PM - 2:30PM	Gray Water & Grease	120	Electric Machine relieved House Connection choke	Turn over to CCTV	155710
30	3/9/2013	Elrino St & Holabird Ave	21224	Rags & Grease	DWO	Patapsco	1:15	9:45AM - 11:00AM	Grease Balls & Brown Water	375	Pressure Jet relieved Mainline choke	Turn over to CCTV	155703
31	3/10/2013	5003 Corley Rd	21207	Rags & Grease	DWO	Gwynns Falls	1:37	6:28PM - 8:05PM	Gray Water, Grease & Debris	388	Pressure Jet relieved Mainline choke	Turn over to CCTV	155762
32	3/10/2013	5326 Wesley Ave	21207	Rags & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Debris & Grease	Evidence of Overflow	Pressure Jet relieved Mainline choke	Left Plumber a notice	155765
33	3/10/2013	5499 Moores Run Dr	21206	Rags & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	155743
34	3/10/2013	Fleet St & S. Quail St	21224	Rags & Grease	DWO	Patapsco	2:24	9:16AM - 11:40AM	Gray Water	288	Pressure Jet relieved Mainline choke	Turn over to CCTV	155741
35	3/12/2013	2115 McHenry St	21223	N/A	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	N/A	155930
36	3/12/2013	4600 White Ave	21214	Rags, Grease & Roots	WVO	Herring Run	0:20	1:55PM - 2:15PM	Clear Colored Water	20	Electric Machine relieved House Connection choke	Possible Root Control	155928
37	3/13/2013	3555 Newland Ave	21216	Rags & Trash	WVO	Herring Run	3:00	10:30AM - 1:30PM	Clear Colored Water	540	Pressure Jet relieved Mainline choke	Turn over to CCTV	156018
38	3/13/2013	Stonewood Rd & Hillen Rd	21251	N/A	WVO	Herring Run	28:00	3/13/13 2:00PM - 3/14/13 6:00PM	Sewer Water	366,000	Overpumping has stopped the overflow	N/A	156048
39	3/14/2013	3906 Groveland Ave	21215	Rags	DWO	Gwynns Falls	1:35	9:25AM - 11:00AM	Heavy Gray Water	95	Electric Machine relieved House Connection choke	Turn over to CCTV	156068
40	3/15/2013	434 S. Augusta Ave	21229	Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris & Feces	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	156154
41	3/15/2013	533 E. Patapsco Ave	21225	Rags & Debris	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	N/A	156131
42	3/15/2013	3321 Spaulding Ave	21215	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	156178
43	3/16/2013	1000 Poplar Hill Rd	21210	Rags, Roots & Grease	DWO	Jones Falls	3:54	3:06PM - 7:00PM	Heavy Gray Water	468	Pressure Jet relieved Mainline choke	Turn over to CCTV	156191
44	3/16/2013	1920 Riggs Ave	21217	Rags & Grease	DWO	Jones Falls	0:17	5:43PM - 6:00PM	Heavy Gray Water	34	Pressure Jet relieved Mainline choke	Turn over to CCTV	156193
45	3/16/2013	3812 Park Heights Ave	21215	Rags & Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	N/A	156204
46	3/17/2013	6218 Lincoln Ave	21209	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	156241
47	3/20/2013	1717 E. Fairmount Ave	21231	Rags, Grease & Mainline Choke	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	156449

SSO Notification List

March 2013

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
48	3/21/2013	527 N. Carrollton Ave	21223	Roots	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	156491
49	3/21/2013	2606 Fleet St	21224	Pipe Break	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	156525
50	3/21/2013	3101 Pulaski Hwy	21205	Rags, Grease & Trash	WVO	Inner Harbor	0:45	9:15AM - 10:00AM	Clear Colored Water	45	Pressure Jet relieved Mainline choke	Turn over to CCTV	156488
51	3/22/2013	4500 W. Rogers Ave	21215	Rags	DWO	Gwynns Falls	1:55	9:34AM - 11:29AM	Not Noted	230	Pressure Jet relieved Mainline choke	Turn over to CCTV	156542
52	3/22/2013	5920 Northwood Dr	21212	Debris	DWO	Herring Run	1:41	6:14PM - 7:55PM	Sewer Water	505	Pressure Jet relieved Mainline choke	Turn over to CCTV	156566
53	3/23/2013	1717 E. Fairmount Ave	21231	Roots & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	156450
54	3/23/2013	3812 Park Heights Ave	21215	Rags & Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	156219
55	3/24/2013	2511 Willow Glen Dr	21209	Rags, Roots & Grease	WVO	Jones Falls	2:17	8:13PM - 10:30PM	Heavy Gray Water	411	Pressure Jet relieved Mainline choke	Turn over to CCTV	156648
56	3/24/2013	4443 Clifton Rd	21216	Roots	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Line is relieving itself	Turn over to CCTV	156625
57	3/24/2013	5001 Hillen Rd	21239	Rags, Roots & Debris	WVO	Herring Run	2:25	11:55AM - 2:20PM	Sewer Water	290	Pressure Jet relieved Mainline choke	Turn over to CCTV	156630
58	3/27/2013	1327 W. Fayette St	21223	Roots	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	156811
59	3/27/2013	2917 Thorndale Ave	21215	Debris	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	N/A	156835
60	3/27/2013	3417 Edmondson Ave	21229	Rags, Grease & Sand, Gravel, Rocks	WVO	Gwynns Falls	2:08	12:22PM - 2:30PM	Heavy Gray Water	384	Pressure Jet relieved Mainline choke	Turn over to CCTV	156806
61	3/27/2013	5715 Hillen Rd	21239	Rags, Roots & Grease	WVO	Herring Run	1:30	10:30AM - 12:00PM	Gray Colored Water	450	Pressure Jet relieved Mainline choke	Turn over to CCTV	156799
62	3/28/2013	201 Deepdene Rd	21210	Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	156852
63	3/28/2013	2104 Eagle St	21223	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	156840
64	3/29/2013	10 E. 26th St	21218	Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	156894
65	3/29/2013	1906 Ramblewood Rd	21239	Rags & Grease	DWO	Herring Run	17:10	3/29/13 6:35PM - 3/30/13 11:45AM	Rags & Grease	3,090	Electric Machine relieved House Connection choke	Turn over to CCTV	156901
66	3/29/2013	2405 W. Patapsco Ave	21230	Rags & Grease	DWO	Baltimore Harbor	4:15	5:40PM - 9:55PM	Sewer Water & Paper Debris	2,550	Pressure Jet relieved Mainline choke	Turn over to CCTV	156897
67	3/30/2013	2654 Miles Ave	21211	Rags & Grease	DWO	Jones Falls	2:25	8:35AM - 11:00AM	Gray Water & Debris	290	Electric Machine relieved House Connection choke	Turn over to CCTV	156917
68	3/31/2013	2401 Harriet Ave	21230	Rags & Grease	WVO	None	Overflow not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	156965
				# WVO	23				TOTAL	383,536	EVIDENCE ONLY	37	