

## SSO Notification List

October 2013

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	10/2/2013	107 W 29th St	21218	N/A	DWO	N/A	Not Witnessed	Overflow not Witnessed	Damp Area	Evidence of Overflow	Pressure Truck Flush Main Line Sewer 150ft Pressure Hose	UAMD	166242
2	10/2/2013	6608 Danville Ave	21224	Rags, Roots	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Drain Cleaning Machine Relieved H/C Choke	UAMD	166172
3	10/4/2013	1700 Linden Ave	21217	Rags, Grease	DWO	Jones Falls	1:53	8:07AM - 10:00AM	Heavy Gray Water	565	Relieved M/L Choke w/ug Press Truck 300ft of 8" San ML	N/A	166459
4	10/4/2013	Dupont Ave & Greenspring Ave	21207	Rags, Grease	DWO	N/A	1:30	5:30PM - 7:00PM	Paper Wet	45	Used Elec Mach	T/O for UAMD to CCTV	166493
5	10/5/2013	943 Montpelier St	21218	Rags	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Drain Cleaning Machine Relieved HC Choke	UAMD	166528
6	10/8/2013	Dupont Ave & Greenspring Ave	21209	Rags, Power Loss, Grease	DWO	Jones Falls	1:30	1:30PM - 3:00PM	Heavy Gray Water	180	Relieved House Conn Choke with Press Truck 12 ft	N/A	166693
7	10/9/2013	2014 Ramsey St	21223	Rags	WVO	N/A	Not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Rel 30ft Elec Machine Cables	UAMD	166720
8	10/8/2013	322 W 28th St	21211	Rags	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Drain Cleaning Machine Relieved H/C Choke	UAMD	166678
9	10/12/2013	7 Charlcote Pl	21218	Roots	WVO	Jones Falls	0:53	6:07PM - 7:00PM	Heavy Gray Water	265	Relieved ML Choke with Press Truck 50ft-200ft of 6 inch, 8 inch	N/A	166944
10	10/12/2013	3116 Baker St	21216	Rags	WVO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved House Conn Choke with Elec Mach 35ft	N/A	166941
11	10/13/2013	527 N Carrollton Ave	21213	Paper	WVO	N/A	Not Witnessed	Overflow not Witnessed	Grey Water	Evidence of Overflow	Left Plumber Notice	UAMD Investigate Notice	166976
12	10/13/2013	3101 Pulaski Hwy	21224	Rags, Grease	WVO	N/A	Not Witnessed	Overflow not Witnessed	Paper	Evidence of Overflow	Rel. House Conn Choke 75ft Elec Mach	UAMD	166991
13	10/13/2013	4224 Falls Rd	21211	Roots	WVO	N/A	Not Witnessed	Overflow not Witnessed	Paper	Evidence of Overflow	Relieved with Electric Mach	UAMD Investigate/CCTV	166972
14	10/14/2013	2301 Windsor Ave	21217	Pipe Break, Roots	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper & Debris	Evidence of Overflow	Rel 30ft Elec Machine Cables	UAMD Bad Bottom of Clean Out	167005
15	10/15/2013	301 Edgevale Rd	21210	Rags	DWO	N/A	Not Witnessed	Overflow not Witnessed	Gray Water	Evidence of Overflow	Rel House Conn Choke 30ft Elec Machine Cables	UAMD	167033
16	10/15/2013	3000 Potee St	21225	Rags, Roots, Other Debris	DWO	N/A	1:05	11:40AM - 12:45PM	Patapsco	130	Pressure Truck Flush & Clean 400ft 10" Sanitary Sewer Main Line	UAMD	167043
17	10/15/2013	462 Roundview Rd	21225	Pipe Break	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper	Evidence of Overflow	Run Electric Mach	By Pass Pumping	167041
18	10/15/2013	2002 E Lombard St	21231	Roots	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper	Evidence of Overflow	Relieved with Jet Pressure	UAMD Investigate/CCTV	167083
19	10/16/2013	931 Montpelier St	21218	N/A	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper	Evidence of Overflow	Relieved with Electric Machine	UAMD/CCTV	167099
20	10/16/2013	1005 N Ellamont St	21216	Rags, Roots, Other Debris	DWO	Gwynns Falls	2:27	11:35AM - 2:02PM	Grey Water	735	Pressure Truck Flush & Rel Main Line Choke 475 ft San Sewer	UAMD	167106
21	10/16/2013	3928 Frisby St	21218	Pipe Break	DWO	N/A	1:05	2:20PM - 3:25PM	Sewer Water	325	Pressure Jet Relieved M/L Choke	UAMD	167121

## SSO Notification List

October 2013

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
22	10/17/2013	421 E 20th St	21218	Broken Old Sewerline	WWO	N/A	Not Witnessed	Overflow not Witnessed	Gray Water and Toilet Paper	Evidence of Overflow	Was old sewer line holding water	Contractor Made Repair	
23	10/17/2013	809 Glen Allen Dr	21229	Unknown	WWO	N/A	Not Witnessed	Overflow not Witnessed	Paper	Evidence of Overflow	Pressure Truck Flush 15ft Direct Connection Found Clear	UAMD	167137
24	10/17/2013	1730 W North Ave	21217	Rags	WWO	N/A	Not Witnessed	Overflow not Witnessed	Paper	Evidence of Overflow	Rel Elec Machine 30ft Cables	UAMD	167168
25	10/17/2013	4300 Robertson Ave	21206	Unknown	WWO	N/A	Not Witnessed	Overflow not Witnessed	Paper	Evidence of Overflow	Pressure Jet Relieved	UAMD Investigate/ CCTV	167248
26	10/21/2013	3406 W Rogers Ave	21215	Unknown	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper Around Clean Out	Evidence of Overflow	Used Elec Mach	CCTV UAMD	167456
27	10/22/2013	2859 Woodbrook	21217	Rags	WWO	N/A	Not Witnessed	Overflow not Witnessed	Paper	Evidence of Overflow	Rel House Conn Choke 30ft Elec Machine Cable	UAMD	167511
28	10/22/2013	4120 Hamilton Ave	21201	Rags	WWO	N/A	Not Witnessed	Overflow not Witnessed	Clear Colored Water if any	Evidence of Overflow	Cleaned Line with Elec Mach	UAMD	167481
29	10/23/2013	1004 Roland Heights Ave	21211	Roots, Other Clean Out Cap	WWO	N/A	Not Witnessed	Overflow not Witnessed	Paper	Evidence of Overflow	Rel 30ft Elec Machine Cable Plumber Notice Clean Out Cap Inside Pipe	UAMD	167586
30	10/23/2013	3921 Maine Ave	21207	Unknown	WWO	N/A	Not Witnessed	Overflow not Witnessed	Gray Colored Water	Evidence of Overflow	Used Elec Mach	UAMD CCTV	167604
31	10/24/2013	400 Edgevale Rd	21210	Rags, Grease	DWO	Jones Falls	1:40	12:29PM - 2:09PM	Heavy Gray Water	200	Relieved ML Choke with Press Truck 175ft of 6" San ML	N/A	167686
32	10/24/2013	508 S Hanover St	21201	Sand Gravel Rocks	DWO	N/A	Not Witnessed	Overflow not Witnessed	Gray Colored Water	Evidence of Overflow	Used Elec Mach	UAMD CCTV	167718
33	10/24/2013	2230 Linden Ave	21217	Rags	DWO	N/A	1:20	5:40PM - 7:00PM	Gray Colored Water	40	Used Elec Mach	UAMD CCTV	167715
34	10/25/2013	1711 Ensor St	21202	Rags, Sand, Gravel, Rocks	DWO	N/A	Not Witnessed	Overflow not Witnessed	Sewer Water in Contractors Ditch	Evidence of Overflow	Pressure Jet Relieved M/L Choke	UAMD	167784
35	10/25/2013	1715 Lancaster St	21223	Rags	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper Wet	Evidence of Overflow	Used Elec Mach	UAMD CCTV	167774
36	10/27/2013	401 Edgevale Rd	21210	Rags, Pipe Break, Roots	DWO	Jones Falls	1:56	12:17PM - 2:13PM	Heavy Gray Water	348	Relieved ML Choke with Press Truck 200ft of 6inch San ML	N/A	167814
37	10/27/2013	3406 W Rogers Ave	21215	Rags, Debris	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper	Evidence of Overflow	Rel HCC 60ft Electric Machine Cables	UAMD	167836
38	10/27/2013	5203 Falls Rd	21210	Rags, Roots	DWO	Jones Falls	2:46	11:14AM - 2:00PM	Heavy Gray Water	332	Relieved ML Choke with Press Truck 210ft of 6inch San ML	Press Truck 210ft of 6inch San ML	167818
39	10/28/2013	200 Enfield Rd	21212	Unknown	DWO	N/A	0:48	10:42AM - 11:30AM	Heavy Gray Water	240	Pressure Truck Relieved Choke	UAMD Investigate/ T/O CCTV	167866
40	10/29/2013	429 N Kenwood Ave	21224	Unknown	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper	Evidence of Overflow	N/A	UAMD Investigate CCTV	167948
41	10/30/2013	3928 Frisby St	21228	Pipe Break	WWO	Jones Falls	12:45	10/30/13 7:15PM - 10/31/13 8:00AM	Sewer Water	7,650	Contractor Pumping Line Down	Contractor Making Repairs	168056
42	10/31/2013	119 S Augusta Ave	21229	Rags, Roots	WWO	N/A	Not Witnessed	Overflow not Witnessed	Paper	Evidence of Overflow	REL HCC Elec Machine	UAMD	168125

## SSO Notification List

October 2013

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
				# WWO	16				TOTAL	11,055	EVIDENCE ONLY	29	