

SSO Notification List

September 2014

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	9/3/2014	1518 N Mount Street	21217	Rags	DWO	N/A	Not Witnessed	Wet around clean out	Evidence of Overflow	Used Elec. Mach.	UAMD	207099
2	9/4/2014	1600 E 28th Street	21218	Roots, debris, Infiltration/Inflow	DWO	N/A	155	Sewer water	775	Pressure jet relieved M/L choke	UAMD	207151
3	9/6/2014	3427 Clifton Avenue	21216	Grease, trash	WVO	Patapsco	80	Heavy Paper	160	Cleaned line with elec mach	UAMD	207454
4	9/6/2014	613 S Paca St	21230	N/A	DWO	N/A	Not Witnessed	N/A	Evidence of Overflow	Relieved house conn choke with elec mach 45ft CCTV 8.7ft to bottom 39.8ft main	N/A	207472
5	9/7/2014	1407 Park Avenue	21217	Rags, trash	DWO	Jones Falls	Not Witnessed	Clear colored water	Evidence of Overflow	Cleaned line with elec mach	UAMD	207553
6	9/9/2014	3411 Clifton Avenue	21216	Grease, debris	DWO	N/A	Not Witnessed	Grey water	Evidence of Overflow	Pressure truck rel. HCC 100ft pressure hose	UAMD	207763
7	9/10/2014	2323 Arunah Avenue	21216	Rags	DWO	N/A	Not Witnessed	Wet around clean out	Evidence of Overflow	Used sewer jet	UAMD	207977
8	9/11/2014	301 Edgevale Road	21210	Debris	DWO	N/A	Not Witnessed	Toilet paper	Evidence of Overflow	Pressure truck rel. from clean out	UAMD	208068
9	9/11/2014	2701 Wilmarco Avenue	21223	Rags, grease, debris	DWO	N/A	300	Heavy gray water	1500	Relieved M/L choke with pressure truck, 200ft of 8" san M/L	N/A	208154
10	9/13/2014	930 S Curley St	21224	Infiltration/Inflow, Cap in cleanout	WVO	Harbor	Not Witnessed	Sewer water, paper debris	Evidence of Overflow	Drain cleaning machine relieved h/c choke	UAMD	208338
11	9/13/2014	5501 Saint Albans Way	21212	Rags, grease	WVO	N/A	Not Witnessed	Wet paper around clean out	Evidence of Overflow	Used elec. mach.	UAMD	208339
12	9/14/2014	2008 Homewood Ave	21218	Rags, roots, grease	DWO	N/A	Not Witnessed	N/A	Evidence of Overflow	Relieved house conn choke with pressure truck 50ft of 6 inch & flush M/L 100ft of 8 inch. No CCTV	N/A	208370
13	9/16/2014	1600 Gough Street	21231	N/A	DWO	N/A	Not Witnessed	Wet around manhole	Evidence of Overflow	Used sewer jet	UAMD	208716
14	9/16/2014	3062 Acension Street	21225	Rags, roots, grease	DWO	Patapsco	236	Gray water	236	pressure truck flush mainline	UAMD	208581
15	9/16/2014	912 Bethune Rd	21225	Rags, grease, trash	DWO	Gwynns Falls	270	Gray colored water	810	Used pressure mach.	UAMD	208701
16	9/18/2014	2649 Marbourne Ave	21230	Roots, grease	DWO	N/A	Not Witnessed	Wet around cleanout	Evidence of Overflow	Used Elec. mach	UAMD	209058
17	9/20/2014	647 W University Pkwy	21210	Rags, trash	DWO	N/A	Not Witnessed	Wet around manhole	Evidence of Overflow	Used pressure machine	OAM	209253
18	9/22/2014	3320 Sequoia Ave	21215	Rags, toilet paper	DWO	N/A	Not Witnessed	Toilet paper	Evidence of Overflow	Ran elec machine 30 ft elec cables	OAM	209395
19	9/22/2014	Dupont Ave & Greenspring Ave	21209	Rags, grease	DWO	N/A	80	Heavy gray water	240	Relieved house choke with pressure truck 70ft of 6inch CCTV 9ft bottom	OAM	209403
20	9/22/2014	1208 Argonne Drive	21218	Roots	DWO	N/A	Not Witnessed	Gray colored water	Evidence of Overflow	Used pressure machine	OAM	209469
21	9/23/2014	312 N Martin Luther King Jr. Blvd	21201	Rags, roots	DWO	N/A	42	Toilet paper and debris	84	Ran elec-machine 60ft Elec-machine cable	UAMD	209570
22	9/24/2014	600 Elliccott Drive	21216	Pipe break	WVO	Gwynns Falls	11867	Heavy gray water	17553.3	By pass and point repair of 10 inch mainline	UAMD	210036
23	9/27/2014	112 Scott St	21201	Rags	DWO	N/A	Not Witnessed	Rags, debris	Evidence of Overflow	Electric machine relieved choke	UAMD	210081
24	9/27/2014	3600 Cottage Ave	21215	Roots	DWO	N/A	Not Witnessed	Paper debris	Evidence of Overflow	Electric machine relieved choke	UAMD	210071
				# WVO	4			TOTAL	21358.3	EVIDENCE ONLY	16	